

WATER HEATER PROCEED NOTICE

Northeast Iowa Community Action Corporation
PO Box 487
Decorah, IA 52101
563-382-8436 Ext. 118 & 119

CLIENT'S NAME

CLIENT'S ADDRESS

CLIENT'S CITY

CLIENT'S PHONE NUMBER

JOB NUMBER:

EVALUATOR'S NAME: TC

OWNER RENTER REPLACEMENT REPAIR

WATER HEATER TYPES: ATMOSPHERIC POWER VENTED ELECTRIC


APPROXIMATE AGE 40 FUEL TYPE NG

COMMENTS: Rusty - Replace w/ 40 gal. NG power vent

CONTRACTOR CERTIFICATION

I certify that I have:

- Replaced the Water Heater per bid.
- Repaired Water Heater per bid.



Contractor's Certification Signature

6-11-14
Date

Pre-Test Results:

Water Heater Stats	Reading	Pass	Fail
Draft	<u>9</u>		
CO (ppm)	<u>1</u>		
Leakage			<input checked="" type="checkbox"/>
Gas Leak	<u>NO</u>		
Efficiency Test			
Termination Side/Direction: <u>East</u>			

EVALUATOR CERTIFICATION

I certify that I have inspected the water heater, and on this date, it functions properly and passes all standards according to the Iowa Weatherization Assistance Program.


Evaluator's Certification Signature

Date

REPLACEMENT INFORMATION

MAKE RHEEM
MODEL PROC485-360N RHE PV
Eff rating e67

OFFICE USE ONLY

Inspector Certification 

Date of Inspection 6/23/14

Make/Model RHEEM PROC485-360N RHE PV

Serial Number RHE NR 491331995

*See reverse side for Iowa Weatherization Assistance Program standards.